

C E R T I F I C A T E
of Conformity



Registration No.: AK 60152733 0001

Report No.: 28119919 001

Holder: Sabiana S.p.A
via Piave 53
20011 Corbetta MI
Italia

Product: Air Conditioner Fan
Built-in indoor hydronic heat exchanger.

Identification: Type: CASSETTE Model: SK xy ECM + -CRY
(see speaking code on the test report)
Rated Voltage : 230 V ; 50 Hz Protection Class : I
Rated Power : 28.5 W + 126 W + 10 W
Inlet water temperature : 6-80°C
Inlet water pressure : 1000 kPa max
Protection degree : IPX0
Storage Nr.: 200338/3 - 200338/4 Trademark : Sabiana

Tested acc. to: IEC 60335-1:2010+A1+A2
IEC 60335-2-40:2018
EN 60335-1:2012+A11+A13+A1+A14+A2
EN 60335-2-40:2003+A11+A12+A1+A2+A13
EN 60335-2-65:2003+A1+A11

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 18.11.2020

Certification Body

Daniele Ricchi


TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg